Worcester County Administration Office
1 West Market Street, Room 1103
Snow Hill, MD 21863
Ph. 410-632-1194

Addendum # 2 (Additional Q&As) – NWAC Concessions, Restrooms & Pavilion Upgrades

Date of Addendum: **November 4, 2026**

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal time has not been changed.

1.0 – ATTACHMENTS

Item	Description

2.0 – CLARIFICATIONS

The following clarifications are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Description

3.0 – QUESTIONS AND ANSWERS

Questions and Answers

4) Please clarify if we should provide an Ansul system for the hood in the proposal.
Yes, an Ansul fire suppression system is required

6) Since the scope of work involves installing a new gas line to the hood location to serve two fryers and a flat-top griddle, we will need equipment submittals for the units you plan to use or a maximum BTU rating that will not be exceeded. This information is necessary to determine the appropriate gas line and gas valve size if an Ansul fire suppression system is to be installed.
Total BTU 180,000: Fryer - 90,000 & Griddle - 90,000

END OF ADDENDUM